

## 2019

### **Water Quality Report** NAVAL AIR STATION JACKSONVILLE

The Naval Facilities Engineering Command Southeast (NAVFAC SE), Public Works Department (PWD), as the Naval Air Station Jacksonville (Station) water utility service provider, is very pleased to provide you with the 2019 Annual Water Quality Report. PWD provides a safe and dependable supply of drinking water through three deep wells which draw from the Floridan Aquifer.

In 2019, the Department of Environmental Protection performed a Source Water Assessment that identified no potential sources of contamination near our wells. Assessment results are on the DEP Source Water Assessment and Protection Program website at [www.dep.state.fl.us/swapp](http://www.dep.state.fl.us/swapp). Treatment of your water supply includes aeration for odor control and chlorination for disinfection. In 2003, Station started receiving potable water from JEA, therefore, some of the data in this report is from JEA testing.

For further information or questions concerning this report, Station housing residents should contact the Housing Office and organizational personnel should contact PWD Jacksonville Utilities, at (904) 542-6440.

PWD Jacksonville routinely monitors for contaminants in your drinking water according to Federal and State laws and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period January 1<sup>st</sup> to December 31<sup>st</sup> 2019. Data obtained before January 1, 2019 and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations.

Below are the definitions of terms and abbreviations used in the report:

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants

**Non-Detects (ND)** – indicates that the substance was not found by laboratory analysis.

**Not Applicable (N/A)** – No value limit or restriction has been applied to this particular parameter.

**Parts per billion (ppb)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per million (ppm)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Treatment Technique (TT)**: A required process intended to reduce the level of a contaminant in drinking water.

**NON-SECONDARY TEST RESULTS TABLE – NAS JACKSONVILLE**

**Radiological Contaminants**

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Gross Alpha (pCi/l) (JEA/NAS)	02/17	N	7.07	ND – 7.07	0	15	Erosion of natural deposits
Radium 226&228 (pCi/l) (JEA/NAS)	02/17	N	1.296	ND – 1.296	0	5	Erosion of natural deposits

**Inorganic Contaminants**

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Antimony (ppb) (JEA only)	02/17	N	0.495	ND – 0.495	6	6	Discharge from petroleum refineries; fire retardants, ceramics; electronics; solder.
Barium (ppm) (JEA/NAS)	02/17, 03/17	N	0.0329	0.0142-0.0341	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Lead (ppb) (JEA only)	02/17	N	1.95	ND – 1.95	0	15	Residue from man-made pollution such as auto emissions and paint; lead pipe; casing and solder
Fluoride (ppm) (JEA/NAS only)	02/17, 03/17	N	0.77	0.27 -0.77	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at optimum levels between 0.7 and 1.3 ppm
Nitrate (as Nitrogen) (JEA only)	3/19	N	0.237	ND-0.237	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nickel (ppb) (JEA only)	02/17	N	2.11	ND – 2.11	N/A	100	Pollution from mining and refining operations; Natural occurrence in soil
Selenium (ppb) (JEA only)	02/17	N	7.83	ND – 7.83	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm) (JEA/NAS)	02/17, 03/17	N	115.15	7.54-115.15	N/A	160	Salt water intrusion, leaching from soil
Thallium (ppb) (JEA only)	02/17	N	0.466	ND – 0.466	0.5	2	Leaching from ore processing sites; discharge from electronics, glass and drug factories

**Stage 2 Disinfectants and Disinfection By-Products**

For chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.

For haloacetic acids or TTHM, the level detected is the highest RAA, computed quarterly, of quarterly averages of all samples collected if the system is monitoring quarterly or is the average of all samples taken during the year if the system monitors less frequently than quarterly. Range of Results is the range of individual sample results (lowest to highest) for all monitoring locations.

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Total Trihalomethanes (TTHM) (ppb)	Quarterly 2019	N	78.62	39.85-99.64	N/A	80	By-product of drinking water chlorination

Haloacetic Acids (HAA5) (ppb)	Quarterly 2019	N	18.9	8.59-24.9	N/A	60	By-product of drinking water chlorination
Chlorine Residual (ppm)	01/19-12/19	N	1.13	0.81-1.4	4	4.0	Water additive used to control microbes

### Secondary Contaminants

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Sulfate (ppm) (NAS/JEA)	02/17, 03/17 and 06/17	**Y	258	22-258	N/A	250	Natural occurrence from soil leaching
Total Dissolved Solids (ppm) (NAS/JEA)	02/17, 03/17, 04/17 and 05/17	**Y	846	141-846	N/A	500	Natural occurrence from soil leaching
Iron (ppm) (JEA only)	02/17, 03/17, 04/17 and 05/17	**Y	0.439	0.003-0.439	N/A	0.3	Natural occurrence from soil leaching
Odor (threshold odor number) (JEA only)	02/17-06/17	**Y	64	1-64	N/A	3	Naturally occurring organics
Chloride (ppm) (JEA only)	02/17-04/17	**Y	329	9-329	N/A	250	Natural occurrence from soil leaching

\*\* While the MCL was exceeded for TDS, Sulfate, Odor, Chloride and Iron, levels recorded for these parameters do not show adverse health effects.

### Lead and Copper (Tap Water) (NAS only)

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation Y/N	90 <sup>th</sup> Percentile Result	No. of sites exceeding the AL	MCL G	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	09/17	N	0.043	0 of 60 sites	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	09/17	N	1.2	0 of 60 sites	0	15	Corrosion of household plumbing systems; erosion of natural deposits

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NAVFAC SE is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2

minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

*Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.*

*Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).*