

2019 Water Quality Consumer Confidence Report

We are pleased to report that our drinking water meets all federal and state requirements. The Annual Water Quality Report (Consumer Confidence Report) is required by the Safe Drinking Water Act (SDWA) and is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality.

Naval Construction Battalion Center (NCBC) Gulfport receives water from the Graham Ferry aquifer. The Graham Ferry aquifer is part of the Miocene aquifer system that consists of multiple layers of sand separated by beds of clay. A U.S. Geological Survey study of groundwater in Harrison County found that aquifers deeper than 500 feet were artesian. The groundwater from NCBC Gulfport water supply is pumped from three wells that are well in excess of 700 feet.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity.

The best mechanism to get involved consists of participating in Housing Residence meetings. The most current information about the meetings may be obtained by contacting the Housing Office at (228) 871-2586 or Belfour Beatty Community at (228) 863-0424.

The CCR will not be mailed to customers, but is posted on the NCBC Gulfport Environmental webpage. A hard copy of the CCR can be obtained from the Center's Environmental Office located in Building 322, Room 103 or by emailing a request for a copy. The PWD Environmental Division encourages all consumers that have concerns or questions to contact them directly at (228) 871-2373.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", MS0240060 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 88%.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. NCBC Gulfport is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing

components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	2	2	2	2019	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	6.47	4.61	6.47	2019	No	By-product of drinking water disinfection
Inorganic Contaminants								
Fluoride (ppm)	4	4	1.08	.5	1.08	2019	No	Water additive which promotes strong teeth;
Sodium (optional) (ppm)	NA		63	53	63	2019	No	Erosion of natural deposits; Leaching

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
1,1,1-Trichloroethane (ppb)	200	200	ND	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	ND	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	ND	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	ND	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	ND	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	ND	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	ND	No	Discharge from chemical and agricultural chemical factories
Dichloromethane (ppb)	0	5	ND	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	ND	No	Discharge from petroleum refineries
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Styrene (ppb)	100	100	ND	No	Discharge from rubber and plastic factories; Leaching from landfills
Toluene (ppm)	1	1	ND	No	Discharge from petroleum factories
Trichloroethylene (ppb)	0	5	ND	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	ND	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	ND	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	ND	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	ND	No	Discharge from industrial chemical factories

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
p-Dichlorobenzene (ppb)	75	75	ND	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	ND	No	Discharge from industrial chemical factories

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Kyle Jones
Address: 2401 Upper Nixon Ave., Bldg 322
Gulfport, MS 39501
Phone: 228-871-2373