

Priority Areas Lead Testing and Corrective Actions May 2019
NAS CORPUS CHRISTI Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 15 ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/16/2019			mm/dd/yyyy	6/13/2019	6/13/2019		9/5/2019	
RESULTS DATE			6/4/2019			mm/dd/yyyy	6/19/2019	6/19/2019		9/10/2019	
DRINKING	CC-PLAY-ALPHA-WFBCOMB-FD (OPA-2)	Softball Field Alpha - Water fountain portion of combo.		NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	CC-PLAY-BRAVO-WFCOMB-FD (OPA-4)	Softball Field Bravo - Water fountain portion of combo.	13	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	CC-PLAY-WALDRON-K-A-FD (OPA-14)	Kitchen faucet in Waldron sports field concession stand	Non Detect								
COOKING	CC-PLAY-WALDRON-K-B-FD (OPA-18)	Kitchen faucet in Waldron sports field concession stand	1.8								
WASHING	CC-PLAY-ALPHA-HOSE-FD (OPA-1)	Softball Field Alpha - Hose Bib	2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-ALPHA-HOSECOMB-FD (OPA-3)	Softball Field Alpha - Hose bib portion of combo.		NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-BRAVO-HOSECOMB-FD (OPA-5)	Softball Field Bravo - Hose bib portion of combo.	16	Yes	6/5/2019	N/A	8.1	2.7	Fixture replaced on 8/21/19.	6.8	N/A
WASHING	CC-PLAY-WALDRON-HOSE-A-FD (OPA-6)	Hose bib in Waldron sports field	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-B-FD (OPA-7)	Hose bib in Waldron sports field	4.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-C-FD (OPA-8)	Hose bib in Waldron sports field	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-D-FD (OPA-9)	Hose bib in Waldron sports field	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-E-FD (OPA-10)	Hose bib in Waldron sports field	8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-F-FD (OPA-11)	Hose bib in Waldron sports field	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-G-FD (OPA-12)	Hose bib in Waldron sports field	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-H-FD (OPA-13)	Hose bib in Waldron sports field	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	CC-PLAY-WALDRON-HOSE-I-FD (OPA-15)	Hose bib in Waldron sports field	16	Yes	6/5/2019	N/A	11.0	0.58	Fixture replaced on 8/22/19. Additional flushing being performed after corrective action to further reduce lead level.	15	N/A

Priority Areas Lead Testing and Corrective Actions May 2019
NAS CORPUS CHRISTI Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			5/16/2019			mm/dd/yyyy	6/13/2019	6/13/2019			9/5/2019
RESULTS DATE			6/4/2019			mm/dd/yyyy	6/19/2019	6/19/2019			9/10/2019
WASHING	CC-PLAY-WALDRON-HOSE-J-FD (OPA-16)	Hose bib in Waldron sports field	16	Yes	6/5/2019	N/A	15.0	0.24	Fixture replaced on 8/22/19.	6.7	N/A
WASHING	CC-PLAY-WALDRON-HOSE-K-FD (OPA-17)	Hose bib in Waldron sports field	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb. on 9/5/19 and final results did not exceed recommended level of 15 ppb.

² Post-remediation sampling was conducted

Priority Areas Lead Testing and Corrective Actions May 2019
NAS CORPUS CHRISTI Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			5/16/2019			mm/dd/yyyy	6/13/2019	6/13/2019		9/5/2019	
RESULTS DATE			6/4/2019			mm/dd/yyyy	6/19/2019	6/19/2019		9/10/2019	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS		POST REMEDIATION RESULTS
	Recommended Level = 15 ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking >15 ppb	0	0	0	0	0
Total Cook/Brush	2	0	0	0	0
Total Cook/Brush >15 ppb	0	0	0	0	0
Total Washing	13	0	3	3	3
Total Washing >15 ppb	3	0	0	0	0
Total Samples	16	0	3	3	3
Total Samples >15 ppb	3	0	0	0	0