FORM 7: SECONDARY CONTAINMENT DRAINAGE LOG

Instructions: All storm water shall be removed from any secondary containment structure within 7 days of a rainfall event. Storm water shall not be discharged without treatment if sheen present. Furthermore, any product in the secondary containment structure must be removed within 3 days of discovery.

Regulatory Driver: 40 CFR 112

Date	Location	Sheen Visible (Y/N)	Product Present (Y/N)	Treatment Employed (Y/N)	Drain Valve Opened (time)	Drain Valve Closed (time)	Comments	Initials