

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Youth Center Building 2069

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	Recommended Level = 15 ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			04/27/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	JAX-2069-HALL-WFCA-FD (BLDG 2069-1)	Fountain In Lobby High, on left	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2069-HALL-WFCB-FD (BLDG 2069 -2)	Fountain In Lobby Low, on right	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX 2069-K-K-FD (BLDG 2069-6)	Kitchen sink behind front desk - Break room	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-BATHW-HHW-FD- (BLDG 2069-3)	Lobby Rest Room Women Restroom sink									
WASHING	JAX-2069-BATHM-HHW-FD- (BLDG 2069-4)	Lobby Rest Room Men Restroom sink									
WASHING	JAX-2069-BATH-M/W-HHW- FD (BLDG 2069-5)	Lobby - rest room sink across from front desk	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-RM1-RM-HHW-FD (BLDG 2069-7)	First room on right Education, yellow room	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-RM2-RM-HHW-FD (BLDG 2069-8)	Second room on right Art, blue room	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-RM3-RM-HHW-FD (BLDG 2069-9)	Third room on right Science, Green room	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-RM4-RM-HHW-FD (BLDG 2069-10)	First room on left Dramatic Play, teal room	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2069-RM5-RM-HHW-FD (BLDG 2069-11)	Second room on left Manipulative, orange room	Non Detect								
WASHING	JAX-2069-BATHWA-MS-FD (BLDG 2069-12)	Ladies Restroom	Non Detect								
WASHING	JAX-2069-BATHWB-MS-FD- (BLDG 2069-13)	Ladies Restroom									
WASHING	JAX-2069-BATHMA-MS-FD (BLDG 2069-14)	Men's Restroom	Non Detect								
WASHING	JAX-2069-BATHMB-MS-FD (BLDG 2069-15)	Men's Restroom	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 15 ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions April 2019
 NAS JACKSONVILLE Youth Center Building 2069

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	Recommended Level = 15 ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			04/272019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS		POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	2	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 15 ppb	0	0	0	0	0
Total Washing	9	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0
Total Samples	12	0	0	0	0
Total Samples > 15 ppb	0	0	0	0	0