

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
DRINKING	JAX-2070-HALL-WFCA-FD (BLDG 2070-1)	Cooler Fountain between restrooms in lobby	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-HALL-WFCB-FD (BLDG 2070-2)	Cooler Fountain between restrooms in lobby	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM130-RM-WFCOMB-FD (BLDG 2070-37)	Pre-school 1 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM132-RM-WFCOMB-FD (BLDG 2070-41)	Pre-school 2 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM134-RM-WFCOMB-FD (BLDG 2070-45)	Pre-school 3 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM136-RM-WFCOMB-FD (BLDG 2070-49)	Pre-school 4 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM138-RM-WFCOMB-FD (BLDG 2070-53)	Pre-school 5 - Lowered bubbler fountain	0.24	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM142-RM-WFCOMB-FD (BLDG 2070-62)	Toddler 5 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM144-RM-WFCOMB-FD (BLDG 2070-66)	Toddler 4 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM146-RM-WFCOMB-FD (BLDG 2070-70)	Toddler 3 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM148-RM-WFCOMB-FD (BLDG 2070-74)	Toddler 2 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-2070-RM150-RM-WFCOMB-FD (BLDG 2070-78)	Toddler 1 - Lowered bubbler fountain	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM129-LOUNGE-K-FD (BLDG 2070-33)	Teacher's lounge/breakroom - Sink for food prep/dish washing	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-HHWA-FD (BLDG 2070-54)	Kitchen sink	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
 NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb							Description	Recommended Level = 15 ppb
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM141-K-HHWB-FD (BLDG 2070-55)	Kitchen, Kitchen hand wash sink	20	Yes	5/16/2019	N/A	16	0.73	Kitchen handwash faucet was permanently removed 6/25/19.	N/A	N/A
COOKING	JAX-2070-RM141-K-KA-FD (BLDG 2070-56)	Kitchen preparation sink	0.57	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-HHWC-FD (BLDG 2070-57)	Kitchen hand wash sink	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	JAX-2070-RM141-K-KB-FD (BLDG 2070-58)	Kitchen preparation sink	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-BATH-HALL-HHWA-MS-FD (BLDG 2070-3)	Adult Only Bathroom	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-BATH-HALL-HHWB-MS-FD (BLDG 2070-4)	Adult Only Bathroom	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM110-RM-HHWA-FD (BLDG 2070-5)	Infant 4	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM110-RM-HHWB-FD (BLDG 2070-6)	Infant 4	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM110-RM-HHWA-MS-FD (BLDG 2070-7)	Infant 4									
WASHING	JAX-2070-RM112-RM-HHWA-FD (BLDG 2070-9)	Infant 5	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM112-RM-HHWB-FD (BLDG 2070-10)	Infant 5	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM114-RM-HHWA-FD (BLDG 2070-11)	Infant 6	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM114-RM-HHWB-FD (BLDG 2070-12)	Infant 6	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb							Description	Recommended Level = 15 ppb
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM116-RM-HHWA-FD (BLDG 2070-13)	Infant 7	0.78	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM116-RM-HHWA-FD (BLDG 2070-14)	Infant 7	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM118-RM-HHWA-FD (BLDG 2070-15)	Pre-Toddler 6	0.82	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM118-RM-HHWA-FD (BLDG 2070-16)	Pre-Toddler 6	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM120-RM-HHWA-FD (BLDG 2070-17)	Pre-Toddler 5	0.87	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb							Recommended Level = 15 ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM120-RM-HHWP-FD (BLDG 2070-18)	Pre-Toddler 5	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM122-RM-HHWA-FD (BLDG 2070-19)	Pre-Toddler 4	0.74	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM122-RM-HHWP-FD (BLDG 2070-20)	Pre-Toddler 4	0.98	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM157-RM-HHWA-FD (BLDG 2070-21)	Pre-Toddler 3	0.83	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM157-RM-HHWP-FD (BLDG 2070-22)	Pre-Toddler 3	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM159-RM-HHWA-FD (BLDG 2070-23)	Pre-Toddler 2	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM159-RM-HHWP-FD (BLDG 2070-24)	Pre-Toddler 2	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM161-RM-HHWA-FD (BLDG 2070-25)	Pre-Toddler 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM161-RM-HHWP-FD (BLDG 2070-26)	Pre-Toddler 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM163-RM-HHWA-FD (BLDG 2070-27)	Infant 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM163-RM-HHWP-FD (BLDG 2070-28)	Infant 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM165-RM-HHWA-FD (BLDG 2070-29)	Infant 2	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM165-RM-HHWP-FD (BLDG 2070-30)	Infant 2	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM167-RM-HHWA-FD (BLDG 2070-31)	Infant 3	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM167-RM-HHWP-FD (BLDG 2070-32)	Infant 3	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-HHWA-FD (BLDG 2070-34)	Pre-school 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-HHWP-FD (BLDG 2070-35)	Pre-school 1	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
	JAX-2070-RM130-RM-HWCMB-FD (BLDG 2070-36)	Pre-school 1, Lowered hand wash	0.82	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
 NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb							Recommended Level = 15 ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019			
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019			
WASHING	JAX-2070-RM132-RM-HHWA-FD (BLDG 2070-38)	Pre-school 2, Faucet with Foot Activated step Lever	1.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-HHWB-FD (BLDG 2070-39)	Pre-school 2, faucet with regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-HWCOMB-FD (BLDG 2070-40)	Pre-school 2, lowered hand wash	3.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM134-RM-HHWA-FD (BLDG 2070-42)	Pre-school 3, Faucet with foot activated step lever	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM134-RM-HHWB-FD (BLDG 2070-43)	Pre-school 3, regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM134-RM-HWCOMB-FD (BLDG 2070-44)	Pre-school 3, Lowered hand wash	0.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM136-RM-HHWA-FD (BLDG 2070-46)	Pre-school 4, Faucet with Foot activated step lever	9.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM136-RM-HHWB-FD (BLDG 2070-47)	Pre-school 4, faucet with regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 15 ppb			Recommended Level = 15 ppb				Recommended Level = 15 ppb	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM136-RM-HWCOMB-FD (BLDG 2070-48)	Pre-school 4, lowered hand wash	1.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM138-RM-HHWA-FD (BLDG 2070-50)	Pre-school 5, faucet with foot activated step lever	1.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM138-RM-HHWA-FD (BLDG 2070-51)	Pre-school 5, faucet with regular had level	0.76	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM138-RM-HWCOMB-FD (BLDG 2070-52)	Pre-school 5, lowered hand wash	0.96	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HHWA-FD (BLDG 2070-59)	Toddler 5, Faucet with foot activated step lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HHWA-FD (BLDG 2070-60)	Toddler 5, Faucet regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM142-RM-HWCOMB-FD (BLDG 2070-61)	Toddler 5, lowered hand wash	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HHWA-FD (BLDG 2070-63)	Toddler 4, faucet with foot activated step lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HHWA-FD (BLDG 2070-64)	Toddler 4, faucet with regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM144-RM-HWCOMB-FD (BLDG 2070-65)	Toddler 4, Lowered hand wash	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HHWA-FD (BLDG 2070-67)	Toddler 3, Faucet with foot activated step lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HHWA-FD (BLDG 2070-68)	Toddler 3, faucet with regular hand lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM146-RM-HWCOMB-FD (BLDG 2070-69)	Toddler 3, lowered had wash	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HHWA-FD (BLDG 2070-71)	Toddler 2, Faucet with foot activated step lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HHWA-FD (BLDG 2070-72)	Toddler 2, faucet with regular hand lever	0.75	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM148-RM-HWCOMB-FD (BLDG 2070-73)	Toddler 2, Lowered hand wash	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM150-RM-HHWA-FD (Bldg 2070-75)	Toddler 1, faucet with activated step lever	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM150-RM-HHWA-FD (BLDG 2070-76)	Toddler 1, Faucet with regulary lever	0.9	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb					Recommended Level = 15 ppb
First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)				Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM150-RM-HWCMB-FD (BLDG 2070-77)	Toddler 1, lowered hand wash	1.7	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM112-RM-LHW-MS-FD (BLDG 2070-79)	Infant 5, Faucet with Motion Sensor	4.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM114-RM-LHW-MS-FD (BLDG 2070-80)	Infant 6 Faucet with Motion Sensor		NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM116-RM-LHW-MS-FD (BLDG 2070-81)	infant 7, Faucet with Motion Sensor	8.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM118-RM-LHW-MS-FD (BLDG 2070-82)	Pre-Toddler 6, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM120-RM-LHW-MS-FD (BLDG 2070-83)	Pre-Toddler 5, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM122-RM-LHW-MS-FD (BLDG 2070-84)	Pre-Toddler 4, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM157-RM-LHW-MS-FD (BLDG 2070-85)	Pre-Toddler 3, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM159-RM-LHW-MS-FD (BLDG 2070-86)	Pre-Toddler 2, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM161-RM-LHW-MS-FD (BLDG 2070-87)	Pre-Toddler 1, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM163-RM-LHW-MS-FD (BLDG 2070-88)	Infant 1, Faucet with Motion Sensor									
WASHING	JAX-2070-RM165-RM-LHW-MS-FD (BLDG 2070-89)	Infant 2, Faucet with Motion Sensor									
WASHING	JAX-2070-RM167-RM-LHW-MS-FD (BLDG 2070-90)	Infant 3, Faucet with Motion Sensor	6.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-BATH-HALL-HWC-MS-FD (BLDG 2070-91)	Adult Only Bathroom, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-BATH-HALL-HWD-MS-FD (BLDG 2070-92)	Adult Only Bathroom, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-LHWA-MS-FD (BLDG 2070-93)	Pre-school 1, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM130-RM-LHWB-MS-FD (BLDG 2070-94)	Pre-school 1, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-95)	Pre-school 2, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 15 ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							mm/dd/yyyy	5/20/2019	5/20/2019
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019		mm/dd/yyyy	
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-96)	Pre-school 2, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-97)	Pre-school 3, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-98)	Pre-school 3, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-99)	Pre-school 4, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-100)	Pre-school 4, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-101)	Pre-school 5, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-102)	Pre-school 5, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-103)	Toddler 5, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-104)	Toddler 5, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-105)	Toddler 4, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-106)	Toddler 4, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-107)	Toddler 3, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-108)	Toddler 3, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-109)	Toddler 2, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-110)	Toddler 2, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWA-MS-FD (BLDG 2070-111)	Toddler 1, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2070-RM132-RM-LHWP-MS-FD (BLDG 2070-112)	Toddler 1, Faucet with Motion Sensor	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
 NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019			mm/dd/yyyy
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019			mm/dd/yyyy

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb.

² Follow up sampling was conducted on 20 May 2019.

Priority Areas Lead Testing and Corrective Actions April 2019
 NAS JACKSONVILLE Child Development Center Building 2070

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			4/27/2019			mm/dd/yyyy	5/20/2019	5/20/2019	mm/dd/yyyy		
RESULTS DATE			5/13/2019			mm/dd/yyyy	5/23/2019	5/23/2019	mm/dd/yyyy		

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	12	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0
Total Cook/Brush	6	0	1	1	0
Total Cook/Brush > 15 ppb	1	0	1	0	0
Total Washing	89	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0
Total Samples	107	0	1	1	0
Total Samples > 15 ppb	1	0	1	0	0