

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Play Areas

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 15 ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							Description		
SAMPLING DATE			4/27/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	JAX-15-PLAY-WFC-FD (OPA-1)	McCaffrey Softball Complex Water cooler	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-BLUE-ANGEL-WFCOMB-FD (OPA-2)	Dr. Gene Page Clubhouse, Blue Angel Field Water fountain hose bib-combo									
DRINKING	JAX-PLAY-BLUE-ANGEL-HOSECOMB-FD (OPA-3)	Dr. Gene Page Clubhouse, Blue Angel Field Water fountain hose bib-combo									
DRINKING	JAX-PLAY-PAGE-WFCOMB-FD (OPA-4)	Page Field Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-PAGE-HOSECOMB-FD (OPA-5)	Page Field Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-DREW-WFCOMBA-FD (OPA-6)	Drew Field Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-DREW-HOSECOMBA-FD (OPA-7)	Drew Field Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-DREW-WFCOMBB-FD (OPA-8)	Drew Field Water fountain hose bib-combo									
DRINKING	JAX-PLAY-DREW-HOSECOMB-FD (OPA-9)	Drew Field Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-RED BARN-WFCOMB-FD (OPA-10)	Field with the red barn Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-RED BARN-HOSECOMB-FD (OPA-11)	Field with the red barn Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 15 ppb							Recommended Level = 15 ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING-	JAX-PLAY-PASS & ID-WFCOMBA-FD (OPA-12)	Baseball field closest to Pass and ID, left side Water fountain hose bib-combo									
DRINKING	JAX-PLAY-PASS&ID-HOSECOMBA-FD (OPA-13)	Baseball field closest to Pass and ID, left side Water fountain hose bib-combo	0.81	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING-	JAX-PLAY-PASS&ID-WFCOMBB-FD (OPA-14)	Baseball field closest to Pass and ID, right side Water fountain hose bib-combo									
DRINKING	JAX-PLAY-PASS&ID-HOSECOMBB-FD (OPA-15)	Baseball field closest to Pass and ID, right side Water fountain hose bib-combo	1.3	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING-	JAX-PLAY-BIRMINGHAM-WFBA-FD (OPA-16)	Baseball field close to Birmingham, side near the pool									
DRINKING-	JAX-PLAY-BIRMINGHAM-WFBB-FD (OPA-17)	Baseball field close to Birmingham, side near woods									
DRINKING-	JAX-PLAY-BIRMINGHAM-HOSEA-FD (OPA-18)	Baseball field close to Birmingham, side near pool									
DRINKING-	JAX-PLAY-BIRMINGHAM-HOSEB-FD (OPA-19)	Baseball field close to Birmingham, side near woods									
DRINKING	JAX-PLAY-BASKETBALL-WFB-FD (OPA-20)	Basketball court Water fountain	6.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING-	JAX-PLAY-WATSON-WFCOMBB-FD (OPA-21)	Baseball field, Watson field.									
DRINKING	JAX-PLAY-WATSON-HOSECOMB-FD (OPA-22)	Baseball field, Watson field.	1.3								
DRINKING	JAX-PLAY-PATRIOT GROVE-WFCA-FD (OPA-23)	Patriots Grove Play ground - High fountain	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-PLAY-PATRIOT GROVE-WFCB-FD (OPA-24)	Patriots Grove Play ground - Low fountain	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)		Recommended Level = 15 ppb	
Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)							First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
SAMPLING DATE			4/27/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	JAX-PLAY-SUBSTATION FIELD-WFCOMB-FD (OPA-25)	Baseball field behind electrical substation Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX PLAY-SUBSTATION FIELD-HOSECOMB-FD (OPA-26)	Baseball field behind electrical substation Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX PLAY-SUBSTATION FIELD-HOSECOMB-FD (OPA-27)	Baseball field behind electrical substation Water fountain hose bib combo	Non-Detect	NO	N/A	N/A	N/A	N/A			
DRINKING	JAX-PLAY-TENNIS-WFC-FD (OPA-28)	Tennis court under tent - Water fountain	1.2	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-Play-Genepage-Hosecomb-FD (OPA-29)		1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-Play-Genepage-WFB-FD (OPA-30)		0.97	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-Play-Birmingham-HoseC-FD (OPA-31)		Non-Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAX-Play-Birmingham-HoseD (OPA-32)		0.88	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	JAS-Play-Watson-Hosecomb-FD (OPA-34)		1.8	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 15 ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions April 2019
NAS JACKSONVILLE Play Areas

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS		
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb			Description	Recommended Level = 15 ppb	
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/27/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
RESULTS DATE			5/13/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	23	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 15 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0
Total Samples	23	0	0	0	0
Total Samples > 15 ppb	0	0	0	0	0