

Priority Areas Lead Testing and Corrective Actions FY24
NAS Jacksonville Gym Building 2066

Table 1 - Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
			Recommended Level = 10 ppb							Recommended Level = 10 ppb	
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE RESULTS DATE			10/26/2024			mm/dd/yyyy	12/19/2024	12/19/2024		4/28/2025	
			11/21/2024			mm/dd/yyyy	1/9/2025	1/9/2025		5/6/2025	
DRINKING	JAX-2066-HALL-WFC-FD	Water fountain in Hall.	0.61	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2066-BATHM-HHWA-FD	Male restroom sink, sink on left.	100	YES	11/21/2024	N/A	5.4	0.5	New faucet installed	2	N/A
WASHING	JAX-2066-BATHM-HHWB-FD	Male restroom sink, sink on right.	10	YES	11/21/2024	N/A	66	0.5	New faucet installed	1.3	N/A
WASHING	JAX-2066-BATHW-HHWA-FD	Women restroom sink, sink on left.	0.93	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	JAX-2066-BATHW-HHWB-FD	Women restroom sink, sink on right.	0.94	NO	N/A	N/A	N/A	N/A		N/A	N/A
Notes: ¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 10 ppb. ² Post-remediation sampling was initially conducted on 4/28/2025. Facuets were replaced and final results below recommended level of 10 ppb for sample collected on 4/28/2025 are shown on the table.											

Priority Areas Lead Testing and Corrective Actions FY24
NAS Jacksonville Gym Building 2066

Table 2 - Summary Statistics

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 10 ppb				
	First Draw	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling	First Draw	Follow up Flush - Collected 30 seconds after First Draw Sampling	First Draw
Total Drinking	1	0	0	0	0
Total Drinking > 10 ppb	0	0	0	0	0
Total Cooking	0	0	0	0	0
Total Cooking > 10 ppb	0	0	0	0	0
Total Washing	4	0	2	2	2
Total Washing > 10 ppb	2	0	1	0	0
Total Samples	5	0	2	2	2
Total Samples > 10 ppb	2	0	1	0	0