

Table 1 - Summary of Results

SAMPLING LOCATION DESCRIPTION					INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
					Recommended Level = 10 ppb							Recommended Level = 10 ppb	
CATEGORY	SAMPLE ID	SAMPLE ID DESCRIPTION	Outlet Description	Comments	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE RESULTS DATE					10/26/2024			mm/dd/yyyy	12/19/2024	12/19/2024		mm/dd/yyyy	
					11/21/2024			mm/dd/yyyy	1/3/2025	1/3/2025		mm/dd/yyyy	
DRINKING	PLAY-1	JAX-15-PLAY-WFC-FD	McCaffrey Softball Complex, water cooler		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-2	JAX-PLAY-PAGE-WFCOMB-FD	Page field, water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-3	JAX-PLAY-PAGE-HOSECOMB-FD	Page field, water fountain hose bib combo		4.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-4	JAX-PLAY-DREW-WFCOMBA-FD	Drew field, water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-5	JAX-PLAY-DREW-HOSECOMBA-FD	Drew field, water fountain hose bib combo		1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-6	JAX-PLAY-DREW-WFCOMBB-FD	Drew field, water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-7	JAX-PLAY-DREW-HOSECOMB-FD	Drew field, water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-8	JAX-PLAY-REDBARN-WFCOMB-FD	Field with the red barn (474J), water fountain hose bib combo		Inoperable	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-9	JAX-PLAY-RED BARN-HOSECOMB-FD	Field with the red barn (474J), water fountain hose bib combo	Hose bib missing	N/A	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-10	JAX-PLAY-PASS-ID-WFCOMBA-FD	Baseball field closest to pass and id, left side, water fountain hose bob combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-11	JAX-PLAY-PASS-ID-HOSECOMBA-FD	Baseball field closest to pass and id, left side, water fountain hose bob combo		9.8	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-12	JAX-PLAY-PASS-ID-WFCOMBB-FD	Baseball field closest to pass and id, right side, water fountain hose bob combo		Inoperable	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-13	JAX-PLAY-PASS ID-HOSECOMBB-FD	Baseball field closest to pass and id, right side. Water fountain hose bib combo		18	Yes	11/21/2024	N/A	0.5	0.5	Not required since re-sample results were below 10 ppb	N/A	N/A
DRINKING	PLAY-14	JAX-PLAY-BIRMINGHAM-WFBA-FD	Birmingham, side near the pool, water fountain		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-15	JAX-PLAY-BIRMINGHAM-HOSEA-FD	Birmingham, side near the pool, hose bib by water fountain		2.4	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-16	JAX-PLAY-BIRMINGHAM-WFBB-FD	Birmingham, side near woods, water fountain		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-17	JAX-PLAY-BIRMINGHAM-HOSEB-FD	Birmingham, side near woods, hose bib by water fountain		1	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-23	JAX-PLAY-POOL-WFC-FD	Between bathrooms at pool, water fountain		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-24	JAX-PLAY-BASKETBALL-WFB-FD	Baseball field, Watson field, water fountain hose bib combo	Could not locate	N/A	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-25	JAX-PLAY-WATSON-WFCOMB-FD	Baseball field, Watson field water fountain hose bib combo		0.64	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-26	JAX-PLAY-WATSON-HOSECOMB-FD	Baseball field, Watson field water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-27	JAX-PLAY-PATRIOT GROVE-WFCA-FD	Patriots Grove Play ground, high fountain		4.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-28	JAX-PLAY-PATRIOT GROVE-WFCB-FD	Patriots Grove Play ground, low fountain		6.9	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-29	JAX-PLAY-SUBSTATION FIELD-WFCOMB-FD	Baseball field behind electrical substation, water fountain hose bib combo		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-30	JAX PLAY-SUBSTATION FIELD-HOSECOMB-FD	Baseball field behind electrical substation, water fountain hose bib combo		1	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-31	JAX PLAY-SUBSTATION FIELD-HOSECOMB-FD	Baseball field behind electrical substation, added between 2014 and 2018	Could not locate	N/A	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	PLAY-32	JAX-PLAY-TENNIS-WFC-FD	Tennis court, under tent, water fountain		1.1	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PLAY-18	JAX-PLAY-POOL-MBATH-HHWA-FD	Men's bathroom sink at pool, restroom sink		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PLAY-19	JAX-PLAY-POOL-MBATH-HHWB-FD	Men's bathroom sink at pool, restroom sink		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PLAY-20	JAX-PLAY-POOL-WBATH-HHWA-FD	Women's bathroom sink at pool, restroom sink		0.6	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PLAY-21	JAX-PLAY-POOL-WBATH-HHWB-FD	Women's bathroom sink at pool, restroom sink		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	PLAY-22	JAX-PLAY-POOL-WBATH-HHWC-FD	Women's bathroom sink at pool, restroom sink		0.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
Notes: ¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 10 ppb. ² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 10 ppb for sample collected on N/A are shown on the table.													

Priority Areas Lead Testing and Corrective Actions FY24  
NAS Jacksonville Outside Play Areas

Table 2 - Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 10 ppb				
	First Draw	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling	First Draw	Follow up Flush - Collected 30 seconds after First Draw Sampling	First Draw
Total Drinking	22	0	1	1	0
Total Drinking > 10 ppb	1	0	0	0	0
Total Cooking	0	0	0	0	0
Total Cooking > 10 ppb	0	0	0	0	0
Total Washing	5	0	0	0	0
Total Washing > 10 ppb	0	0	0	0	0
Total Samples	27	0	1	1	0
Total Samples > 10 ppb	1	0	0	0	0