

Priority Areas Lead Testing and Corrective Actions May 2019
NAS FORT WORTH JRB School Age Care Center Building 1145

Table 1. Summary of Results

| SAMPLING LOCATION DESCRIPTION | | | INITIAL SAMPLING RESULTS | | | RE-SAMPLING RESULTS | | | CORRECTIVE ACTIONS | POST REMEDIATION SAMPLING RESULTS | | |
|---------------------------------|---|---|--------------------------|------------------|------------------------------------|----------------------------|------------|-------------|--------------------|--|------------------|--|
| | | | First Draw (ppb) | Retest required? | Date Fixture Secured? (See Note 1) | Recommended Level = 15 ppb | | Description | | Recommended Level = 15 ppb | | |
| CATEGORY Water Intended For: | SAMPLE ID | Outlet Description | | | | | | | | Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) | First Draw (ppb) | Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| SAMPLING DATE | | | 5/11/2019 | | | | mm/dd/yyyy | 11/8/2014 | 11/8/2014 | 11/24/2014 | | |
| RESULTS DATE | | | 5/28/2019 | | | | mm/dd/yyyy | 11/13/2014 | 11/13/2014 | 11/26/2014 | | |
| COOKING | FW-1145-K-KA-FD (BLDG 1145-1) | Side by side kitchen faucet Faucet | 1.6 | NO | N/A | N/A | N/A | N/A | | N/A | N/A | |
| COOKING | FW-1145-K-KB-FD (BLDG 1145-2) | Side by side kitchen faucet Faucet | 1.2 | NO | N/A | N/A | N/A | N/A | | N/A | N/A | |
| WASHING | FW-1145-BATH-GIRLS-HHW-FD (BLDG 1145-4) | Girls bathroom, Handwash sink in bathroom | 1.1 | NO | N/A | N/A | N/A | N/A | | N/A | N/A | |
| WASHING | FW-1145-BATH-BOYS-HHW-FD | Boys bathroom, Handwash sink in bathroom | 1.1 | NO | N/A | N/A | N/A | N/A | | N/A | N/A | |
| WASHING | FW-1145-RM-HHW-FD (BLDG 1145-5) | Single handwash sink in general play area | 1.4 | NO | N/A | N/A | N/A | N/A | | N/A | N/A | |

Priority Areas Lead Testing and Corrective Actions May 2019
NAS FORT WORTH JRB School Age Care Center Building 1145

Table 2. Summary Statistics

| CATEGORY | INITIAL SAMPLING RESULTS | RE-SAMPLING RESULTS | | | POST REMEDIATION RESULTS |
|---------------------------|----------------------------|--|------------------|---|--------------------------|
| | Recommended Level = 15 ppb | | | | |
| | First Draw (ppb) | Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb) | First Draw (ppb) | Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) | First Draw (ppb) |
| Total Drinking | 0 | 0 | 0 | 0 | 0 |
| Total Drinking > 15 ppb | 0 | 0 | 0 | 0 | 0 |
| Total Cook/Brush | 2 | 0 | 0 | 0 | 0 |
| Total Cook/Brush > 15 ppb | 0 | 0 | 0 | 0 | 0 |
| Total Washing | 3 | 0 | 0 | 0 | 0 |
| Total Washing > 15 ppb | 0 | 0 | 0 | 0 | 0 |
| Total Samples | 5 | 0 | 0 | 0 | 0 |
| Total Samples > 15 ppb | 0 | 0 | 0 | 0 | 0 |