

Priority Areas Lead Testing and Corrective Actions May 2019
NAS Key West OPAs (Ball Field, Dog Park, Splash Park)

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb			Description	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			5/18/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			6/5/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	KW-V4245-BALLFLD-WFC-FD (Ball Field-1)	Building at Ball Fld. Water Cooler at building	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	KW-DOGPARK-WFC-FD	Dog Park. Water fountain at Dog Park (Dog Park-1)	Non Detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING											
WASHING	KW-V4245-BALLFLD-HOSE-FD (Ball Field-2)	Building at Ball Fld. Hose outlet at building	14	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	KW-SPLASHPARK-BATH-HHW-FD (Splash Park-1)	Bathroom. Bathroom at splash park	5.4	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15 ppb.

² Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 15 ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions May 2019
NAS Key West OPAs (Ball Field, Dog Park, Splash Park)

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 15 ppb				Description	Recommended Level = 15 ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			5/18/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			6/5/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Recommended Level = 15 ppb			First Draw (ppb)
		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
Total Drinking	2	0	0	0	0
Total Drinking > 15 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 15 ppb	0	0	0	0	0
Total Washing	2	0	0	0	0
Total Washing > 15 ppb	0	0	0	0	0
Total Samples	4	0	0	0	0
Total Samples > 15 ppb	0	0	0	0	0