

Priority Areas Lead Testing and Corrective Actions June 2018
 Naval Construction Battalion Center Gulfport Teen Center Building 335A

| Table 1. Summary of Results | | | | | | | | | | | | | |
|--|--|---|---------------------------------|-----------|--------------------|---------------------|------------------|-----------------------|--------------------|------------|-----------------------------------|------------|------------|
| SAMPLING LOCATION DESCRIPTION | | | INITIAL SAMPLING RESULTS | | | RE-SAMPLING RESULTS | | | CORRECTIVE ACTIONS | | POST REMEDIATION SAMPLING RESULTS | | |
| | | | CATEGORY Water Intended For: | SAMPLE ID | Outlet Description | First Draw (ppb) | Retest required? | Date Fixture Secured? | | | Recommended Level = 20ppb | | |
| Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) | | | | | | | | | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy |
| SAMPLING DATE | | | 6/30/2018 | | | | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | | | mm/dd/yyyy | |
| RESULTS DATE | | | 7/26/2018 | | | | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | | | mm/dd/yyyy | |
| DRINKING | GPT-335A-RM06-HALL-WFC-A-FD (BLDG 335A - 12) | Fountain by computer room Cooler fountain in Teen Center | 1.30 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |
| DRINKING | GPT-335A-RM06-HALL-WFC-B-FD (BLDG 335A - 13) | Fountain by computer room Cooler fountain in Teen Center | 1.40 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |
| WASHING | GPT-335A-UBATH-MSHHW-A-FD (BLDG 335A- 14) | Unisex Bathroom in very back from Entrance Motion Sensor Faucet | 1.60 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |
| WASHING | GPT-335A-UBATH-MSHHW-B-FD (BLDG 335A- 15) | Unisex Bathroom to the right of 335A-14 Motion Sensor Faucet | 1.60 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |
| WASHING | GPT-335A-UBATH-MSHHW-C-FD (BLDG 335A- 16) | Unisex Bathroom to the right of 335A-15 Motion Sensor Faucet | 1.40 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |
| WASHING | GPT-335A-UBATH-HHW-FD (BLDG 335A- 17) | Unisex Bathroom to the right of 335A-16 High hand wash sink | 1.40 | NO | N/A | N/A | N/A | N/A | | | | N/A | N/A |

Priority Areas Lead Testing and Corrective Actions June 2018
 Naval Construction Battalion Center Gulfport Teen Center Building 335A

| SAMPLING LOCATION DESCRIPTION | | | INITIAL SAMPLING RESULTS | | | RE-SAMPLING RESULTS | | | CORRECTIVE ACTIONS | POST REMEDIATION SAMPLING RESULTS | |
|---------------------------------|-----------|--------------------|--------------------------|------------------|-----------------------|--|------------------|--|--------------------|-----------------------------------|--|
| CATEGORY Water Intended For: | SAMPLE ID | Outlet Description | First Draw (ppb) | Retest required? | Date Fixture Secured? | Recommended Level = 20ppb | | | | Description | Recommended Level = 20ppb |
| | | | | | | Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) | First Draw (ppb) | Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) | First Draw (ppb) | | Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) |
| SAMPLING DATE | | | 6/30/2018 | | | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | | mm/dd/yyyy | |
| RESULTS DATE | | | 7/26/2018 | | | mm/dd/yyyy | mm/dd/yyyy | mm/dd/yyyy | | mm/dd/yyyy | |

Table 2. Summary Statistics

| CATEGORY | INITIAL SAMPLING RESULTS | RE-SAMPLING RESULTS | | | POST REMEDIATION RESULTS |
|-------------------------|---------------------------|--|------------------|--|--------------------------|
| | Recommended Level = 20ppb | | | | |
| | First Draw (ppb) | Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb) | First Draw (ppb) | Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) | First Draw (ppb) |
| Total Drinking | 2 | 0 | 0 | 0 | 0 |
| Total Drinking > 20 ppb | 0 | 0 | 0 | 0 | 0 |
| Total Washing | 4 | 0 | 0 | 0 | 0 |
| Total Washing > 20 ppb | 0 | 0 | 0 | 0 | 0 |
| Total Samples | 6 | 0 | 0 | 0 | 0 |
| Total Samples > 20 ppb | 0 | 0 | 0 | 0 | 0 |