

Priority Areas Lead Testing and Corrective Actions June 2018
 Naval Construction Battalion Center Gulfport Youth Center Building 335

Table 1. Summary of Results												
SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS		POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb						Description	Recommended Level = 20ppb		
			First Draw (ppb)	Retest required?	Date Fixture Secured?	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	
SAMPLING DATE			6/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy	
RESULTS DATE			7/26/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy			mm/dd/yyyy	
DRINKING	GPT-335-RM103-HALL-WFC-FD (BLDG 335 - 7)	Fountain by game room in hallway Cooler fountain	non-detect	NO	N/A	N/A	N/A	N/A			N/A	N/A
COOKING	GPT-335-RM111-K-K-FD (BLDG 335 - 8)	Kitchen Food prep sink	2.20	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-A-FD (BLDG 335 - 1)	Men's Bathroom High hand wash sink	0.71	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-B-FD (BLDG 335 - 2)	Men's Bathroom High hand wash sink	non-detect	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM123-BATH-HHW-C-FD (BLDG 335 - 3)	Men's Bathroom High hand wash sink	non-detect	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-A-FD (BLDG 335 - 4)	Women's Bathroom High hand wash sink	1.50	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-B-FD (BLDG 335 - 5)	Women's Bathroom High hand wash sink	3.40	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM119-BATH-HHW-C-FD (BLDG 335 - 6)	Women's Bathroom High hand wash sink	1.20	NO	N/A	N/A	N/A	N/A			N/A	N/A
WASHING	GPT-335-RM111-K-HHW-FD (BLDG 335 - 10)	Kitchen Hand wash sink	4.00	NO	N/A	N/A	N/A	N/A			N/A	N/A

Priority Areas Lead Testing and Corrective Actions June 2018
 Naval Construction Battalion Center Gulfport Youth Center Building 335

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured?	Recommended Level = 20ppb				Description	Recommended Level = 20ppb
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			6/30/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			7/26/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Recommended Level = 20ppb				
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	1	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	7	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	9	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0