

Priority Areas Lead Testing and Corrective Actions September 2018  
NS Guantanamo Bay OUTDOOR PLAY AREAS - COOPER FIELD

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Description	Recommended Level = 20ppb
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb) (See note 2)		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
<b>SAMPLING DATE</b>			9/15/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
<b>RESULTS DATE</b>			10/9/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	GTMO-2181B-PLAY-COOPER-WFCA-FD (OPA -1)	Cooper Field - Fountains attached to central building at Cooper Field Sports Complex	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	GTMO-2181B-PLAY-COOPER-WFCB-FD (OPA -2)	Cooper Field - Fountains attached to central building at Cooper Field Sports Complex	non-detect	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

<sup>2</sup> Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions September 2018  
NS Guantanamo Bay OUTDOOR PLAY AREAS - COOPER FIELD

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 20ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			9/15/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE			10/9/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	0	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	0	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	2	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0