

Priority Areas Lead Testing and Corrective Actions September 2018  
Naval Support Activity MID-SOUTH Youth Center Building 936

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	Recommended Level = 20ppb							Recommended Level = 20ppb	
			First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		Description	First Draw (ppb) (See note 2)
SAMPLING DATE			8/18/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
RESULTS DATE			8/7/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
DRINKING	MDS-936-HALL-WFCA-FD (BLDG 936-7)	Fountain across from lockers / Lower fountain on the left	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
DRINKING	MDS-936-HALL-WFCB-FD (BLDG 936-8)	Fountain across from lockers / Higher fountain on the right	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
COOKING	MDS-936-K-K-FD (BLDG 936-5)	Kitchen Sink	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-BATH-M-HHWA-FD (BLDG 936-1)	Men's bathroom by entrance sink on left	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-BATH-M-HHWB-FD (BLDG 936-2)	Men's bathroom by entrance sink on right	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-BATH-W-HHWA-FD (BLDG 936-3)	Women's bathroom by entrance sink on left	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-BATH-W-HHWB-FD (BLDG 936-4)	Women's bathroom by entrance sink on right	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-BATH-UNISEX-HHW- FD (BLDG 936-6)	Staff Unisex Bathroom sink by Admin room	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-RM2-RM-HHWA-FD (BLDG 936-9)	Activity Room 2 High sink	1.5	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-RM2-RM-HHWB-FD (BLDG 936-10)	Activity Room 2 High sink	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-RM1-RM-HHWA-FD (BLDG 936-11)	Activity Room 1 High sink	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-RM1-RM-HHWB-FD (BLDG 936-12)	Activity Room 1 High sink	Not Detected	NO	N/A	N/A	N/A	N/A		N/A	N/A
WASHING	MDS-936-HOSE-FD (BLDG 936- 13)	Hose bib outside attachment by west entrance	3.7	NO	N/A	N/A	N/A	N/A		N/A	N/A

Notes:

<sup>1</sup> Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.

<sup>2</sup> Post-remediation sampling was initially conducted on N/A. Additional N/A were implemented and final results below recommended level of 20ppb for sample collected on N/A are shown on the table.

Priority Areas Lead Testing and Corrective Actions September 2018  
Naval Support Activity MID-SOUTH Youth Center Building 936

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY Water Intended For:	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Recommended Level = 20ppb				Description	First Draw (ppb) (See note 2)
						Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)			
SAMPLING DATE			8/18/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		
RESULTS DATE			8/7/2018			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS	RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)	Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2	0	0	0	0
Total Drinking > 20 ppb	0	0	0	0	0
Total Cook/Brush	1	0	0	0	0
Total Cook/Brush > 20 ppb	0	0	0	0	0
Total Washing	10	0	0	0	0
Total Washing > 20 ppb	0	0	0	0	0
Total Samples	13	0	0	0	0
Total Samples > 20 ppb	0	0	0	0	0