



DEPARTMENT OF THE NAVY

NAVAL SUPPORT ACTIVITY MID-SOUTH
5722 INTEGRITY DRIVE
MILLINGTON, TN 38054-5045

December 11, 2020

MEMORANDUM

From: Commanding Officer, Naval Support Activity Mid-South
To: Naval Support Activity Mid-South

Subj: PERFLUOROALKYL AND POLYFLUOROALKYL SUBSTANCES RESULTS
NOTIFICATION

1. The safety and health of our Sailors and their families at Naval Support Activity (NSA) Mid-South are our top priority. I am informing you of the results of the drinking water testing conducted on-site on October 13, 2020 in response to the March 2020 Secretary of Defense Policy for Perfluoroalkyl and Polyfluoroalkyl Substances (PFAS) sampling in DOD owned water systems.

2. I am pleased to report that drinking water testing results for PFAS was below the method reporting limit for all compounds tested, including non-detect results for Perfluorooctanoic Acid and Perfluorooctanoic Sulfate.

3. While PFAS are considered "emerging contaminants" for which there are no Safe Drinking Water Act regulatory standards, Navy policy requires this testing in an effort to ensure the safety and health of all our military and civilian personnel. Based upon the sampling results, the installation will be required to resample the drinking water in three years.

4. If you have immediate concern, please contact Amanda Moreno, NSA Mid-South Public Affairs Officer at Amanda.r.moreno@navy.mil or (901)282-2322.

A handwritten signature in black ink, appearing to read "A. J. ROSS", is written over the typed name. The signature is stylized and cursive.

A. J. ROSS